

PATRICIA A. PESHKA

PURCHASING AGENT



SCOTT AVEDISIAN

MAYOR

CITY OF WARWICK

PURCHASING DIVISION
3275 POST ROAD
WARWICK, RHODE ISLAND 02886
TEL (401) 738-2000 EXT. 6240
FAX (401) 737-2364

To: All Prospective Bidders

From: Patricia A. Peshka, Purchasing Agent

Date: September 28, 2016

Re: **Bid2017-128 Cooper Building Fire Alarm Upgrades Phase IV**

Addendum #1

Please be advised that the information provided comprises Addendum # 1.

This project shall be completed within 90 days.

The bid opening remains on Wednesday, October 12, 2016 at 11 AM in the Lower Level Conference Room at City Hall.

Thank you for your interest in this project.

TO: All Bidders
FROM: Joseph J. Watson, PE, Jensen Hughes
SUBJECT: Bid #2017-128 Fire Alarm Upgrades Cooper Building
DATE: September 28, 2016
CC: Joseph Blake – City of Warwick

Please include the following clarifications to the City of Warwick Phase IV Fire Alarm plans (Bid #2017-128). This document shall supplement Construction Documents dated August 26, 2016.

The Contractor shall complete the following scope of work:

1. Is exposed conduit permitted and if so, is it required to be painted?

The Contractor shall be permitted to run exposed conduit. Conduit is not required to be painted to match existing conditions. Cover plates and junction boxes for all fire alarm system conduit shall be painted red.

2. The Contractor shall be responsible for painting or replacing the existing red cover plates located on the telecom conduits throughout the building, such that they are not mistaken for fire alarm system conduit.

3. The Contractor shall be responsible for removing the existing local manual pull station and alarm bell located next to the boiler room door in the first floor corridor. The use of blank cover plates shall be permitted. Paint color for cover plates shall be coordinated with the city of Warwick.

4. The Contact Information for the City of Warwick's Honeywell representative is as follows:

William (Bill) Place
Account Executive
2000 Plainfield Pike
Cranston, RI 02921
Email: William.place@honeywell.com
Office: 401-275-2658
Mobile: 401-640-6652

All bidders must acknowledge acceptance of this addendum in their bid.

Please do not hesitate to contact our office with any questions.