



**RHODE ISLAND
DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF WATER RESOURCES**

May 3, 2023

Mr. Robert Schiavo
Skydra Development, LLC
858 Washington St. Suite #305
Dedham, MA 02026

**RE: WQC/STW File No. 23-017; UIC File No. 000615; RIPDES RIR102489
Post Road Apartments
2119 Post Road
Warwick Rhode Island
Assessor's Plat 323, Lot 523**

Dear Mr. Schiavo:

The Rhode Island Department of Environmental Management Office of Water Resources (RIDEM OWR) has reviewed the above-referenced project for compliance with the RIDEM Stormwater Management, Design and Installation Rules (Stormwater Rules: 250-RICR-150-10-8) and the RIDEM Groundwater Discharge (GWD)/Underground Injection Control (UIC) Program (Groundwater Discharge Rules: 250-RICR-150-05-4) and the Rhode Island Pollutant Discharge Elimination System Construction General Permit (CGP). The applicant proposes to construct and maintain two four-story residential buildings, an amenity courtyard, parking, and associated stormwater best management practices. The stormwater management system consists of Cascade® proprietary pretreatment devices, subsurface isolator row systems, and 5 subsurface infiltration systems. The project is as further described in your application and detailed on the site plans stamped by Brandon Carr P.E., as prepared by DiPrete Engineering, received by RIDEM OWR on 2/7/2023.

This letter serves as your permit for the above-referenced project, provided that you comply with the application materials, the Stormwater Rules, the Groundwater Discharge Rules, and the following conditions:

- 1) You must submit the Notice of Start of Construction Form prior to commencement of any permitted site alterations or construction activity. The Start of Construction Form can be found on the Stormwater Construction Permitting website.
- 2) Prior to construction, you must erect or post a sign resistant to the weather and at least twelve (12) inches wide and eighteen (18) inches long, which identifies the initials "DEM" and the application number(s) assigned to this permit. The sign must be posted in a conspicuous location near the site access and maintained until the project is complete.
- 3) A copy of this permit, any inspection records, and a signed and updated erosion and sediment control plan, must be kept at the site at all times until the project is complete. Copies of this permit must be made available for review by any RIDEM or City Town representative upon request. Electronic versions of required documents that are readily accessible from the construction site are acceptable.
- 4) All fill material shall be clean and free of matter that could cause pollution of the waters of the State.
- 5) The stormwater collection and treatment system approved herein is for the discharge of stormwater only. Any other discharge is prohibited.

- 6) Any alterations, additions or modifications to the stormwater system from that approved herein, including permanent closure must be reviewed and approved by the RIDEM OWR prior to being implemented.
- 7) You must notify RIDEM OWR upon completion of the project and final site stabilization.
- 8) You are responsible for the long-term inspection, cleaning and maintenance of the stormwater collection and treatment system to ensure proper performance of all components until documentation is provided to indicate that this responsibility has been assumed by another entity. Long-term operation and maintenance is to be as described in the Post-Construction Operation and Maintenance Plan entitled "Stormwater System Operation & Maintenance Plan 2119 Post Road located in Warwick, RI Applicant: Skydra Development, LLC" dated 1-23-2023, prepared by DiPrete Engineering.
- 9) Prior to the start of any site redevelopment, all remaining existing UICs that are not to remain active at the site must be properly closed out and/or removed according to the UIC Rules Closure process. Please contact Neal Personeus of the UIC Program at neal.personeus@dem.ri.gov for any questions or assistance.

This UIC/GWD Registration will expire 4 years from the date of issuance if the stormwater discharge system has not been constructed and installed. Once a registration is expired, a new application must be submitted for any proposed activity subject to the Groundwater Discharge Rules. Your authorization to discharge under the CGP expires at midnight on September 25, 2025. If construction has not been completed by that date, there will be measures in place for you to reauthorize.


RIDEM's Rules and Regulations Governing the Establishment of Various Fees require that RIPDES CGP permit holders pay an Annual Fee of \$100.00. An invoice will be sent to the owner on record in May/June of each year if the construction was still active as of December 31st of the previous year. The owner will be responsible for the Annual Fee until the construction activity has been completed, the site has been properly stabilized, and a completed Notice of Termination (NOT) has been received.

You are required to adhere to all above terms and conditions, and carry out this project in compliance with the Stormwater Rules and Groundwater Discharge Rules at all times. Issuance of this permit does not bar RIDEM, or any of its various Divisions, from initiating any investigation and/or enforcement actions that it may deem necessary for violations of this permit or of any and all applicable statutes, regulations and/or permits.

This permit has the full force and effect of a permit issued by the Director. This permit does not relieve your obligation to obtain any other applicable local, state and federal permits prior to commencing construction and does not relieve you of any duties owed to adjacent landowners with respect to changes in drainage. RIDEM assumes no responsibilities for damages resulting from faulty design or construction.

If you have any questions regarding the contents of the permit, you may contact Joseph Camara at joseph.camara@dem.ri.gov or (401) 222-4700, extension 2777640.

Sincerely,



Nicholas A. Pisani, P.E.
Environmental Engineer IV
Rhode Island Department of Environmental Management
Office of Water Resources - Stormwater Engineering and 401 Permitting

ec: Brandon Carr, DiPrete Engineering
Neal Personeus, RIDEM