

Patricia A. Peshka
Purchasing Agent



Frank J. Picozzi
Mayor

City of Warwick
Purchasing Division
3275 Post Road
Warwick, Rhode island 02886
Tel (401) 738-2013
Fax (401) 737-2364

To: All Prospective Bidders
From: Patricia A. Peshka, Purchasing Agent
Date: February 7, 2022
Re: **Bid2022-284 Water Tank Rehabilitation**

Addendum #1

=====

Please be advised that the information provided comprises of Addendum #1.

After the mandatory pre-bid conference held on Thursday, February 3, 2022, there were clarifications about the scope of work. Potential bidders should note the following.

Representatives Present: Chris Bolton, G.S. Bolton
Joe Pappo, DN Tanks

Project Specifications

Installation of a 30” Diameter Wall Access Manway in 5.5 MG Tank

Design, furnish and install a new 30” diameter watertight wall manway through the tank wall at existing grade complete with a ladder to access the tank floor and grab bar above the opening inside the tank.

Work to include:

- Shop drawings and calculations stamped by a professional engineer in the State of Rhode Island, experienced in the design of AWWA D110 Type 3 tanks.
- Layout and evaluation of the tank prior to installation
- Coring through the tank side wall of the tank

- Strengthening the side wall of the tank by restoring the prestressing wire at the opening and installing new reinforced concrete encasements on the interior and exterior wall surfaces.
- Installation of the new 30" diameter stainless steel manway system
- Installation of new fiberglass manway ladder and a grab bar above the manway on the interior to allow access to the tank floor

Sealed bids will be received by the Purchasing Division, Warwick City Hall, 3275 Post Road, Warwick, Rhode Island 02886 up until 11:00 AM, Tuesday, February 15, 2022.

Should you have any questions, please contact Terry DiPetrillo, Water Division Chief, at 401-921-9798.

Thank you for your interest in this project.