

FRANCIS M. GOMEZ
PURCHASING AGENT



FRANK J. PICOZZI
MAYOR

CITY OF WARWICK
PURCHASING DIVISION
3275 POST ROAD
WARWICK, RHODE ISLAND 02886
TEL (401) 738-2013
FAX (401) 737-2364

To: All Prospective Bidders

From: Francis M. Gomez, Purchasing Agent

Date: January 5, 2023

Re: **Bid2023-305 Thayer Arena Roof Replacement and or Repairs**

Addendum #3

=====

Please be advised that the information provided comprises of Addendum #1.

General Project Information

Roof Plan Changes

1. Addition of drip edge/gutters, downspouts, and splash blocks on the northwest and southeast perimeter of Roof E. The entire perimeter of Roof E will receive the specified drip edge/gutter assembly. The northwest run will receive two (2) 6" x 5' PVC downspouts and concrete splash blocks. The southeast run will receive two (2) 6" x 30' PVC downspouts and concrete splash blocks.
2. Roof A is not included (NIC) in scope of work/bid.

Attachment: Thayer Arena Roof

Should you have any questions, please contact Eric Earls, DPW Director, at eric.j.earls@warwickri.com.

Thank you for your interest in this project.