


PATRICIA A. PESHKA  
PURCHASING AGENT



JOSEPH J. SOLOMON  
MAYOR

**CITY OF WARWICK**  
PURCHASING DIVISION  
3275 POST ROAD  
WARWICK, RHODE ISLAND 02886  
TEL (401) 738-2013  
FAX (401) 737-2364

To: All Prospective Bidders

From: Patricia A. Peshka, Purchasing Agent 

Date: August 21, 2019

Re: **RFP2020-124 Conimicut Village Crosswalks, Streetscapes & Public Space Improvements**

**Addendum #1**

---

Please be advised that the information provided comprises Addendum # 1.

After the mandatory pre-bid meeting held on Wednesday, August 14, 2019, there were a few questions regarding the specifications and scope of work. Potential bidder should note the following.

1. Only representatives who were present at the pre-bid meeting are eligible to submit proposals.

**Representatives:** Bob Swenson, Cardi Corp.  
David Skurka, Skurka Construction  
Tim Walsh, D'Ambra Construction  
Nate Gagnon, Yard Works  
Steve Bakios, East Coast Contruction

**2. General Project Information**

- A. Project related questions must be submitted no later than **Thursday, August 22, 2019 @ 4:30 PM.** Questions may be sent by e-mail to [lucas.murray@warwickri.com](mailto:lucas.murray@warwickri.com). Any questions received after this date and time will not be addressed.

**Continued next page**

- B. Bidders must ensure they submit all federal forms as outlined in the bid package (refer to the section following 32 33 00 for more details). In addition, all bidders shall include pages 2, 3, and Section 00 41 13 as part of their bid submission. Please review all instructions carefully to ensure all of the forms are properly completed and submitted as required.

**3. Bidder Questions and Answers as of 8/20/2019**

Q- Exhibit A calls out the color of the crosswalks as solid 'Tan' in color but Exhibit B calls out "solid brick red" paint color. Which color is correct?

A – The color of all crosswalks shall be solid brick red. Final color shall be selected by the Owner from standard manufacturer selections. Color swatches shall be submitted to the Owner for final approval.

Q- I assume that traffic control and cop details will not be required for Bids #2 and #3?

A – Traffic control is at the discretion of the bidder for items #2 and #3 depending on their assessed need of utilizing roadway space to complete work as required. There is parking along the sides of West Shore Road for a majority of the work zone. Therefore the need for a traffic control detail may be limited depending on the bidders approach to the work effort. If the bidder determines a police detail is required to properly conduct work as required, he/she shall include the cost of all police details as part of their lump sum bid.

Q - On Exhibit B- Area A- is A labeled in the correct location?

A – Yes. It is the corner opposite the park at the corner of West Shore Road and Beach Avenue where a large tree resides in the middle of a brick plaza. The picture correlates with the area and work effort.

Q-Brick work that is to be done on the corners of West Shore Rd and Beach Ave, is it all corners that the brick are to be power washed and jointed with polymeric sand or just the two corners showcased on Exhibit B (areas A & I)?

A- All corners that are brick are to be power washed, jointed with polymeric sand, and sealed. This includes areas A, I, and the northwest side of Beach Avenue opposite the church property. Please note that all brick shall be sealed in accordance with the drawings and specifications.

Should you have any questions regarding this proposal, please contact Lucas Murray, City of Warwick Planning Department, at 401-921-9683 or [Lucas.Murray@warwickri.com](mailto:Lucas.Murray@warwickri.com).

Thank you for your interest in this project.