

**SECTION 00 9112  
ADDENDUM NUMBER 2**

**PARTICULARS**

**1.01 DATE: MARCH 12, 2021**

**1.02 PROJECT: RENOVATIONS TO WARWICK PUBLIC LIBRARY CHILDREN'S RESTROOMS**

**1.03 OWNER: WARWICK PUBLIC LIBRARY**

**1.04 ARCHITECT: ED WOJCIK ARCHITECT, LTD.**

**TO: PROSPECTIVE BIDDERS:**

**2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL PROCUREMENT DOCUMENTS DATED FEBRUARY 22, 2021, AND ADDENDUM NUMBER 01 ISSUED MARCH 3, 2020, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.**

**2.02 THIS ADDENDUM CONSISTS OF 1 PAGE AND THE FOLLOWING ATTACHMENTS:**

- A. 00 4323 ALTERNATES FORM
- B. 01 2300 ALTERNATES
- C. 08 1416 FLUSH WOOD DOORS

**2.03 CLARIFICATIONS:**

- A. BID BOND IS **NOT** REQUIRED FOR THIS PROJECT, LABOR AND MATERIALS BOND IS REQUIRED.
- B. OWNER WOULD PREFER TO USE STAIRS IN SOUTHEAST CORNER FOR DEMOLITION ACTIVITIES. CONTRACTOR RESPONSIBLE FOR PROTECTING EXISTING FINISHES.

**CHANGES TO THE PROJECT MANUAL - BID #2021L-04: CHILDREN'S RESTROOM RENOVATION:**

**3.01 SEALED BIDS WILL BE RECEIVED IN THE ADMINISTRATIVE OFFICE, WARWICK PUBLIC LIBRARY, 600 SANDY LANE, WARWICK, RI 02889 UNTIL 1:00 PM ON WEDNESDAY, MARCH 24, 2021. OFFICE IS LOCATED ON SECOND FLOOR ACROSS LOBBY FROM CHILDREN'S DEPARTMENT.**

**3.02 ALL QUESTIONS PERTAINING TO THESE SPECIFICATIONS SHOULD BE REFERRED TO JANA STEVENSON, DIRECTOR, E-MAIL: JANALYNNSTEVENSON@GMAIL.COM**

**CHANGES TO THE PROJECT MANUAL - SPECIFICATIONS:**

**4.01 SECTION 09 5100 - ACOUSTICAL CEILINGS**

- A. 2.03.A. Delete "hold down clips".

**CHANGES TO DRAWINGS:**

**5.01 DRAWING A-2 - INTERIOR ELEVATIONS, SCHEDULES**

- A. ACCESSORY SCHEDULE, KEY 4, TOILET PARTITIONS, SEE BELOW.

**5.02 APPROVAL OF ADDITIONAL PRODUCTS/SYSTEMS:**

- A. TOILET PARTITIONS -
  - 1. BASIS OF DESIGN: ACCURATE PARTITIONS, SOLID PLASTIC (HDPE)
  - 2. SUBSTITUTIONS: SCRANTON PRODUCTS, HINY HIDERS PARTITIONS, SOLID PLASTIC (HDPE); [www.scrantonproducts.com](http://www.scrantonproducts.com)

**END OF SECTION**

**SECTION 00 4323  
ALTERNATES FORM**

**PARTICULARS**

**1.01 THE FOLLOWING IS THE LIST OF ALTERNATES REFERENCED IN THE BID SUBMITTED BY:**

**1.02 (BIDDER) \_\_\_\_\_**

**1.03 TO (OWNER ): WARWICK PUBLIC LIBRARY**

**1.04 DATED \_\_\_\_\_ AND WHICH IS AN INTEGRAL PART OF THE BID FORM.**

**ALTERNATES LIST**

**2.01 THE FOLLOWING AMOUNTS SHALL BE ADDED TO OR DEDUCTED FROM THE BID AMOUNT. REFER TO SECTION 01 2300 - ALTERNATES.**

**ALTERNATE # 1: ADD / (DEDUCT) \$ \_\_\_\_\_**

**END OF SECTION**

**SECTION 01 2300  
ALTERNATES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Description of Alternates.
- B. Procedures for pricing Alternates.
- C. Documentation of changes to Contract Price and Contract Time.

**1.02 RELATED REQUIREMENTS**

- A. Document 00 4323 - Alternates Form: List of Alternates as supplement to Bid Form.

**1.03 ACCEPTANCE OF ALTERNATES**

- A. Alternates quoted on Bid Forms will be reviewed and accepted or rejected at Owner's option. Accepted Alternates will be identified in the Owner-Contractor Agreement.

**1.04 SCHEDULE OF ALTERNATES**

- A. Alternate No. 1 - Replace Door Nos. 01 and 02:
  - 1. Base Bid Item: Existing Door Nos. 01 and 02 to Remain \_\_\_\_\_ and Drawing number A-1 including \_\_\_\_\_.
  - 2. Alternate Item: Section 08 1416 and Drawing number A-1 including \_\_\_\_\_.

**PART 2 PRODUCTS - NOT USED**

**PART 3 EXECUTION - NOT USED**

**END OF SECTION**

**SECTION 08 1416  
FLUSH WOOD DOORS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Flush wood doors; flush configuration; non-rated.

**1.02 RELATED REQUIREMENTS**

- A. Section 08 7100 - Door Hardware.

**1.03 REFERENCE STANDARDS**

- A. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards; 2014, with Errata (2018).
- B. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards, U.S. Version 3.1; 2016, with Errata (2018).

**1.04 SUBMITTALS**

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Indicate door core materials and construction; veneer species, type and characteristics.
- C. Shop Drawings: Show doors, elevations, sizes, types, swings, undercuts, beveling, blocking for hardware, factory machining, factory finishing, and other details.
- D. Samples: Submit two samples of door veneer, 6 by 6 inch (152 by 152 mm) in size illustrating wood grain, stain color, and sheen.
- E. Warranty, executed in Owner's name.

**1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section, with not less than three years of documented experience.

**1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Package, deliver and store doors in accordance with specified quality standard.
- B. Accept doors on site in manufacturer's packaging, and inspect for damage.
- C. Protect doors with resilient packaging sealed with heat shrunk plastic; do not store in damp or wet areas or areas where sunlight might bleach veneer; seal top and bottom edges with tinted sealer if stored more than one week, and break seal on site to permit ventilation.

**1.07 WARRANTY**

- A. See Section 01 7800 - Closeout Submittals, for additional warranty requirements.
- B. Interior Doors: Provide manufacturer's warranty for the life of the installation.
- C. Include coverage for delamination of veneer, warping beyond specified installation tolerances, defective materials, and telegraphing core construction.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Wood Veneer Faced Doors:
  - 1. Eggers Industries; \_\_\_\_: [www.eggersindustries.com/#sle](http://www.eggersindustries.com/#sle).
  - 2. Graham Wood Doors; \_\_\_\_: [www.grahamdoors.com/#sle](http://www.grahamdoors.com/#sle).
  - 3. Masonite Architectural; Aspiro Select Wood Veneer Doors: [www.architectural.masonite.com/#sle](http://www.architectural.masonite.com/#sle).
  - 4. Substitutions: See Section 01 6000 - Product Requirements.

**2.02 DOORS**

- A. Doors: See drawings for locations and additional requirements.

1. Quality Standard: Custom Grade, Heavy Duty performance, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
  2. Wood Veneer Faced Doors: 5-ply unless otherwise indicated.
- B. Interior Doors: 1-3/4 inches (44 mm) thick unless otherwise indicated; flush construction.
1. Provide solid core doors at each location.
  2. Wood veneer facing with factory transparent finish.

### **2.03 DOOR AND PANEL CORES**

### **2.04 DOOR FACINGS**

- A. Veneer Facing for Transparent Finish: Species to match existing, veneer grade in accordance with quality standard indicated, plain sliced (flat cut), with book match between leaves of veneer, center balance match of spliced veneer leaves assembled on door or panel face.
1. Vertical Edges: Any option allowed by quality standard for grade.

### **2.05 DOOR CONSTRUCTION**

- A. Fabricate doors in accordance with door quality standard specified.
- B. Factory machine doors for hardware other than surface-mounted hardware, in accordance with hardware requirements and dimensions.
- C. Factory fit doors for frame opening dimensions identified on shop drawings, with edge clearances in accordance with specified quality standard.
- D. Provide edge clearances in accordance with the quality standard specified.

### **2.06 FINISHES - WOOD VENEER DOORS**

- A. Finish work in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), Section 5 - Finishing for grade specified and as follows:
1. Transparent:
    - a. System - 1, Lacquer, Nitrocellulose.
    - b. Stain: As selected by Architect.
    - c. Sheen: Satin.
- B. Factory finish doors in accordance with approved sample.
- C. Seal door top edge with color sealer to match door facing.

### **2.07 ACCESSORIES**

- A. Door Hardware: See Section 08 7100.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Do not install doors in frame openings that are not plumb or are out-of-tolerance for size or alignment.

### **3.02 INSTALLATION**

- A. Install doors in accordance with manufacturer's instructions and specified quality standard.
- B. Factory-Finished Doors: Do not field cut or trim; if fit or clearance is not correct, replace door.
- C. Use machine tools to cut or drill for hardware.
- D. Coordinate installation of doors with installation of frames and hardware.

### **3.03 TOLERANCES**

- A. Comply with specified quality standard for fit and clearance tolerances.
- B. Comply with specified quality standard for telegraphing, warp, and squareness.

**3.04 ADJUSTING**

- A. Adjust doors for smooth and balanced door movement.
- B. Adjust closers for full closure.

**END OF SECTION**